

## Power Terminal Block **145x408**

Replace "x" with 1, 2 or 3 for number of poles.



### Wire Range

- Line: (2) 500 kcmil - #6 AWG
- Load: (12) #2 - #14 AWG

### Electrical Ratings

- 760 Amps
- 600V per UL 1953 & CSA 22.2 No.158, class B & C requirements
- SCCR of 10,000 A (default for terminal blocks).
- CU7AL - 75°C connector terminal rating with copper or aluminum wire
- Factory & Field Wiring


### Agency Compliance

- cULus - UL Listed, investigated to UL 1953, UL File QPOS.E309401 and UL evaluated to CSA 22.2 No 158 File no. QPOS7.309401
- CSA - certified to C22.2 No. 158, File No. LR19766 (wire classes B & C only)
- CE compliant to IEC 60947-7-1


### Material Information

- Insulator base:
  - Thermoplastic
  - Flammability rating of insulator base UL94V0
  - Insulator base temperature rating: -40°C to 125°C (UL RTI)
- Connector: aluminum, tin plated
- Line terminal set screws: aluminum, tin plated
- Load terminal set screws: steel, nickel plated
- Connector mounting screws: steel, zinc plated
- RoHS compliant

## Termination Specifications

Line Side	Wire Size (CU Stranded)	Torque	Wires / Terminal	Wire Class (UL) <sup>1</sup>
	500 kcmil	42.4 N·m (375 lbf·in)	1	B, C
	400	42.4 N·m (375 lbf·in)	1	B, C, G, H
	350 - 2	42.4 N·m (375 lbf·in)	1	B, C, G, H, I (DLO)
	4	42.4 N·m (375 lbf·in)	1	B, C

- Aluminum wire range: 500kcmil - #6 AWG
- Wire strip length: 1 5/8 in. (41mm)
- Terminal screw drive: 3/8 in. hex

Load Side	Wire Size (CU Stranded)	Torque	Wires / Terminal	Wire Class (UL) <sup>1</sup>
	2 AWG	5.6 N·m (50 lbf·in)	1	B, C
	4 - 6	5.1 N·m (45 lbf·in)	1	B, C, G, H, I (DLO)
	8	4.5 N·m (40 lbf·in)	1 - 2 <sup>2</sup>	B, C, G, H, I (DLO)
	10	4 N·m (35 lbf·in)	1 - 2	B, C, I (DLO)
	12 - 14	4 N·m (35 lbf·in)	1 - 2	I (DLO)
			1 - 4	B, C

- Solid copper wire range: #10 - 14
- Aluminum wire range: #4 - #14 AWG
- Wire strip length:
  - top row: 5/8 in. (16mm)
  - bottom row: 1 1/8 in. (29mm)
- Terminal screw drive - slotted

<sup>1</sup> For information on copper stranded wire classes please visit:  
<http://www.marathonsp.com/blog/flexible-stranded-wire.php>

<sup>2</sup> Multiple wire rating applies to class B, C, & I.

## Installation & Accessories

- Mounting (Panel):
  - For use with 1/4 fastener.
  - Mounting torque to be determined in end use application not to exceed 40 lbf-in (4.5 Nm)
  
- Covers:
  - Snap on cover available upon request
  - Catalog number:
    - For 3 pole (1453xxx), CC1453
    - For 2 pole (1452xxx), CC1452
    - For 1 pole (1451xxx), CC1451
  - Cover is black thermoplastic

## Drawing

